

平成23年度 型式別・人員比とBODの関係

型式	人員比 >0.0~		0.3<~		0.5<~		0.7<~		計
	<=0.3		<=0.5		<=0.7		<=1.0		
A	82.6%		88.3%		76.5%		63.6%		76.4%
超小容量型	( 57 / 69 )		( 83 / 94 )		( 75 / 98 )		( 77 / 121 )		( 292 / 382 )
B	85.6%		82.2%		66.7%		54.9%		70.3%
超小容量型	( 89 / 104 )		( 106 / 129 )		( 72 / 108 )		( 96 / 175 )		( 363 / 516 )
C	96.4%		80.3%		70.6%		50.0%		69.3%
複合型	( 53 / 55 )		( 57 / 71 )		( 48 / 68 )		( 61 / 122 )		( 219 / 316 )
D	77.0%		76.1%		65.9%		64.9%		69.2%
複合型	( 47 / 61 )		( 83 / 109 )		( 85 / 129 )		( 122 / 188 )		( 337 / 487 )
D	100.0%		75.0%		84.6%		38.1%		67.2%
超小容量型	( 7 / 7 )		( 15 / 20 )		( 11 / 13 )		( 8 / 21 )		( 41 / 61 )
F	72.2%		78.2%		57.1%		47.9%		62.9%
複合型	( 13 / 18 )		( 43 / 55 )		( 28 / 49 )		( 23 / 48 )		( 107 / 170 )
G	90.0%		71.4%		75.0%		33.3%		62.1%
コンパクト型	( 9 / 10 )		( 5 / 7 )		( 15 / 20 )		( 7 / 21 )		( 36 / 58 )
H	100.0%		33.3%		52.6%		66.7%		60.3%
複合型	( 6 / 6 )		( 4 / 12 )		( 10 / 19 )		( 24 / 36 )		( 44 / 73 )

平成23年度 構造種別・人員比とBODの関係

型式	人員比 >0.0~		0.3<~		0.5<~		0.7<~		計
	<=0.3		<=0.5		<=0.7		<=1.0		
高度処理型	89.5%		100.0%		86.4%		53.6%		77.2%
	( 17 / 19 )		( 10 / 10 )		( 19 / 22 )		( 15 / 28 )		( 61 / 79 )
基準型	100.0%		0.0%		100.0%		0.0%		75.0%
	( 1 / 1 )		( 0 / 1 )		( 2 / 2 )		( 0 / 0 )		( 3 / 4 )
超小容量型	85.8%		82.8%		73.8%		57.8%		73.1%
	( 169 / 197 )		( 217 / 262 )		( 177 / 240 )		( 197 / 341 )		( 760 / 1,040 )
複合型	85.7%		76.3%		63.6%		57.3%		67.3%
	( 132 / 154 )		( 196 / 257 )		( 180 / 283 )		( 236 / 412 )		( 744 / 1,106 )
コンパクト型	94.4%		84.6%		68.8%		34.9%		61.3%
	( 17 / 18 )		( 11 / 13 )		( 22 / 32 )		( 15 / 43 )		( 65 / 106 )
小容流調型	71.4%		28.6%		42.9%		21.4%		38.1%
	( 5 / 7 )		( 2 / 7 )		( 6 / 14 )		( 3 / 14 )		( 16 / 42 )
合計	86.1%		79.3%		68.5%		55.6%		69.4%
	( 341 / 396 )		( 436 / 550 )		( 406 / 593 )		( 466 / 838 )		( 1,649 / 2,377 )

一般家庭(専用住宅)における実使用人員の不明分を含めた全検査基数に対する適合率

構造種別	基準型	高度処理型	超小容量型	複合型	コンパクト型	小容流調型	合計
BOD<=20	4	80	829	826	76	18	1,833
検査基数	5	102	1,137	1,242	121	45	2,652
適合率	80.0%	78.4%	72.9%	66.5%	62.8%	40.0%	69.1%

◎表の見方、処理方式の説明はこちらをご覧ください。(クリックすると説明ページに移ります)

本データの無断引用、転載はお断りします